

Ms. coolant water  
boiled away, the  
reactor's fuel



**ASSIGN  
BUSTER**

Ms. CooperU.

S. History II19 march 2004Three Mile IslandThree Mile Island is a nuclear power plant located in Harrisburg, PA. It had two pressurized water reactors. One in which began its service in 1974 and is the best performing reactor in the US. However its other reactor is almost brand new and suffered a severe nuclear meltdown. March 28th 1979 at approximately 4:00 a. m. a minor malfunction created a rise in temperature to the primary coolant.

The reactor shut down as a safety result. In no time a pilot-operated relief valve (PORV) on the reactor's cooling system opened but did not close. This caused reactor coolant water to leak out and soon drained the tank of its coolant (Wikipedia). As a result of the lost coolant, high pressure pumps pushed replacement water into the reactor system. Water and steam then escaped through its relief valve as cooling water surged to the reactor. In this type of situation, the operators were trained to reduce the flow of the replacement water. Their training told them that the pressurizer water level was the only dependable indication of the amount of cooling water in the system. Because the pressurizer level was increasing, they thought the reactor system was too full of water. They were told to do all they could to keep the pressurizer from filling with water.

If it filled, they could not control pressure in the cooling system and it might rupture. Operators responded by reducing the flow of replacement water. Steam then formed in the reactor cooling system. Pumping a mixture of steam and water caused the reactor cooling pumps to vibrate. If the severe vibrations could have damaged the pumps they would have made them unusable,

<https://assignbuster.com/ms-coolant-water-boiled-away-the-reactors-fuel/>

so the operators shutdown the pumps. This ended the forced cooling of the reactor.

However, as reactor coolant water boiled away, the reactor's fuel core wasuncovered and became even hotter. The fuel rods were damaged and releasedradioactive material into the cooling water. At 6: 22 am operators closed ablock valve between the relief valve and the pressuriser. This actionstopped the loss of coolant water through the relief valve. However, superheated steam and gases blocked the flow of water through the corecooling system (Wikipedia).

By late afternoon, operators began high-pressureinjection of water into the reactor cooling system to increase pressure andto collapse steam bubbles. By 7: 50 pm, they restored forced cooling of thereactor when they were able to restart one reactor coolant pump. They hadcondensed steam so that the pump could run without severe vibrations. FromMarch 29 and 30, operators used a system of pipes and compressors to movethe gas to waste gas decay tanks(Wikipedia).

The compressors leaked, andsome radioactive gas was released to the environmentAfter an anxious month, on 27 April operators established naturalconvection circulation of coolant. The reactor core was being cooled by thenatural movement of water rather than by mechanical pumping. The plant wasin " cold shutdown". The cleanup of the damaged nuclear reactor system at TMI-2 took nearly12 years and cost approximately \$973 million. The Plant surfaces had to bedecontaminated. Any water used and stored during the cleanup had to beprocessed. And about 100 tones of damaged

uranium fuel had to be removed from the reactor vessel — all without hazard to cleanup workers or the public. (Wikipedia) Opinion I see Three Mile Island as history repeating itself; It reminded me a lot of the Titanic.

The crew on Titanic and in the operators room were told that an accident was nearly impossible so that when something happened they didn't know how to react properly or knew entirely what was going on. However, they responded with their instincts which only made the problem worse. Unlike the Titanic though, no one died in Three Mile Island. The Three Mile Island incident was in a way a good lesson to the US in working with nuclear generated power. We saw that it is a force of nature that is very powerful. Its dangers are very real, anything could happen, and if something did happen when using the nuclear power many could die.

We saw that we should not assume anything in a time of delicate decisions [http://en.wikipedia.com/wiki/Three\\_Mile\\_Island](http://en.wikipedia.com/wiki/Three_Mile_Island), Wikipedia, Joan , last modified 02: 19, 15 Mar 2004 The plant's main feedwater pumps in the secondary non-nuclear cooling system failed at about 4: 00 a.

m. on March 28, 1979. This failure was due to either a mechanical or electrical failure and prevented the steam generators from removing heat. First the turbine, then the reactor automatically shut down. Immediately, the pressure in the primary system (the nuclear portion of the plant) began to increase. In order to prevent that pressure from becoming excessive, the pressurizer relief valve (a valve located at the top of the pressurizer) opened. The valve should have closed when the pressure decreased by a certain

amount, but it did not. Signals available to the operator failed to show that the valve was still open.

As a result, the stuck-open valve caused the pressure to continue to decrease in the system. Meanwhile, another problem appeared elsewhere in the plant. The emergency feedwater system (backup to main feedwater) was tested 42 hours prior to the accident. As part of the test, a valve is closed and then reopened at the end of the test. But this time, through either an administrative or human error, the valve was not reopened — preventing the emergency feedwater system from functioning. The valve was discovered closed about eight minutes into the accident. Once it was reopened, the emergency feedwater system began to work correctly, allowing cooling water to flow into the steam generators. As the system pressure in the primary system continued to decrease, voids (areas where no water is present) began to form in portions of the system other than the pressurizer.

Because of these voids, the water in the system was redistributed and the pressurizer became full of water. The level indicator, which tells the operator the amount of coolant capable of heat removal, incorrectly indicated the system was full of water. Thus, the operator stopped adding water. He was unaware that, because of the stuck valve, the indicator could, and in this instance did, provide false readings. After almost eighty minutes of slow temperature rise the primary loop pumps begin to shudder as steam rather than water began to pass through them. The pumps were shut down, and it was believed that natural circulation would continue the water movement.

Steam in the system locked the primary loop, and as the water stopped circulating it was converted to steam in increasing amounts. After around 130 minutes since the first malfunction, the top of the reactor core was exposed and the heat and steam drove a reaction involving hydrogen and other radioactive gases with the zirconium rod cladding. The quench tank ruptured, and radioactive coolant began to leak out into the general containment building. At 6 a. m. there was a shift change in the control room.

A new arrival noticed that the temperature in the holding tanks was excessive and used a backup valve to shut off the coolant venting. Around 250, 000 gallons (950 m) of coolant had already been lost from the primary loop. It was not until 165 minutes after the start of the problem that radiation alarms activated as contaminated water reached detectors, by which time the radiation levels in the primary coolant water were around 300 times expected levels.